

# Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

## **Intertek WH US Mark for Category B - Doors - Additional Edge-sealing System Required**

Standards: UL 10(c) (2016), UL 10(b) (2008) (R2015), NFPA 252 (2017), UL 10(b) (2008) (R2020)

Certificate number: WHI23-39147701

**Organization:** AMERICAN MOTORS – CH. PILALIS S.A.  
5, Protomagias Street, Industrial Zone, Krioneri  
Athens, Attica 14568  
Greece

**Product:** AMP - Cold Room Fire Door “FireFreeze” - 90 Minutes - UL 10C

*Spec ID:* 74696

*Fire Rating:* 90 Min PP Category B Door, 60 Min PP Category B Door


*Listing Information:* See following page(s)

**Certification body:** Intertek Testing Services NA, Inc.

**Initial registration:** November 01, 2023

**Date of expiry:** December 31, 2024

**Issue status:** 2

**Authorized By:**   
**Jean-Philippe Kayl, Director of Certification**

Intertek Testing Services NA, Inc.  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320

[www.intertek.com](http://www.intertek.com)

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

## LISTING INFORMATION

### Product Covered

AMP - Cold Room Fire Door "FireFreeze" - 90 Minutes - UL 10C  
CATEGORY B DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED.

### Product Description

Latched Single Acting Single Leaf Hinged Cold Room Fire Door "FireFreeze"

#### Tested Sizes:

Single leaf door: 1170 x 2275 x 120mm (w x h x thk.)

#### Limitations:

Minimum Latch Throw - 19mm (Listed surface mounted rim type panic device).

Door surface can be coated with rigid PVC with maximum thickness of 200 microns.

### Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **90 minutes (1-1/2 hours)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).

Note: Doors must be installed in listed AMP Category C steel frames or listed Category C standard frames.

# Certificate of Compliance



You have been awarded:

## **Intertek WH US Mark for Category C - Proprietary Frames**

Standards: UL 10(c) (2016), UL 10(b) (2008) (R2015), NFPA 252 (2022)


Certificate number: WHI23-39147702

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

**Organization:** AMERICAN MOTORS – CH. PILALIS S.A.  
5, Protomagias Street, Industrial Zone, Krioneri  
Athens, Attica 14568  
Greece

**Product:** AMP - Cold Room Fire Door Frame “FireFreeze” - 90 Minutes - UL 10C  
*Spec ID:* 74697  
*Fire Rating:* 60 Min PP Category C Proprietary Frame, 90 Min PP Category C Proprietary Frame  
*Listing Information:* See following page(s)

**Certification body:** Intertek Testing Services NA, Inc.  
**Initial registration:** November 21, 2023  
**Date of expiry:** December 31, 2024  
**Issue status:** 2

**Authorized By:**   
**Jean-Philippe Kayl, Director of Certification**

Intertek Testing Services NA, Inc.  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320

[www.intertek.com](http://www.intertek.com)

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

## LISTING INFORMATION

### Product Covered

AMP - Cold Room Fire Door Frame "FireFreeze" - 90 Minutes - UL 10C  
Category C - Proprietary Frames.

### Product Description

Latched Single Acting Single Leaf Hinged Cold Room Fire Door "FireFreeze"

### Tested Sizes:

Single leaf door frame: 1384 x 2392mm (w x h x thk.)

### Limitations:

Door frame must be infilled with mineral wool or cement grouting.

### Fire Ratings

The product noted above has been evaluated according to the requirements of the standard UL 10C and has qualified for up to **90 minutes (1-1/2 hours)** positive pressure fire rating.

Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating).